

Corrigendum/Addendum : RFP Reference No.: NHB/ITD/RFP-DR Colocation/OUT00461/2021 Request for proposal (RFP) for Co-location of Bank's Disaster Recovery Site & Services

S. No	RFP Ref Page no	RFP Clause no	Existing RFP Text	New RFP Text	Category
1	11	4.4. Racks and Cabling, Point number 4	4. Each rack to be provided with two numbers of power strips of 32amps with min. 24 sockets (21no - C13 & 3no - C19), each power strip connected to separate UPS.	4. Each rack to be provided with two numbers of power strips of 32amps (Three phase) with min. 24 sockets (21no - C13 & 3no - C19), each power strip connected to separate UPS.	Corrigendum
2	15	4.2 General Requirements & 4.11 - Power	4.11. Sr. No. 3. : Excerpt: Backup generators should be capable of providing power continuously for at least 48 hours and even during refilling period of fuel tanks.	May be read as: Backup generators should be capable of providing power continuously for at least 24 hours and even during refilling period of fuel tanks.	Corrigendum
3	21	6. PERIOD of CONTRACT	The period of contract may be extended for another 5 years based on discretion of Bank. Please note that in case the contract period is extended, the price variation of 10% is allowed from the applicable quoted unit prices in commercial bid exclusive of taxes.	The period of contract may be extended for another 5 years based on discretion of Bank. Please note that in case the contract period is extended, terms & conditions along with commercial rate (excl. of taxes) will be decided with mutual consent.	Corrigendum
4	33	7.40. Restriction on procurement from a Bidder of a country which shares a land border with India:	The Bidder shall also submit a certificate as per the format enclosed as Annexure XVIII.	May be read as : The Bidder shall also submit a certificate as per the format enclosed as Annexure T	Corrigendum
5	47	11.26	New Clause	11.26 : Please note that consortium is not allowed for this RFP.	Addendum

-:Information Technology Deptt